Grease separator EasyClean free NS 15, Standard

Article information

Item no.: 93015.01
GTIN:
Price group: 60

Advantages

- Can be retrofitted up to Auto Mix & Pump
- Low-maintenance operation

Description

The separator for greasy wastewater is suitable for free-standing set-up in frost-protected rooms and comes without metallic components in the tank. The collecting tank made of permanently resistant polymer (PE) is equipped with an integrated sludge trap and has slopes in the tank base for fast and clean disposal. Two odour-tight covers with quick-release closures make easy access possible for cleaning and maintenance work.

Manual disposal is carried out with the tank open.

20 year polyethylene warranty.
Installation situation: free-standing set-up

Version:

Type of disposal:	manual with suction hose
Disposal variant:	Standard
Refill inlet in accordance with DIN 1988:	no
Nominal size (NS):	15
Inspection window:	no
Shredder-Mix-System:	no
SonicControl:	no
Load-bearing capacity (DIN 19901):	F3
Delivery state:	Installation-ready (connection parts must be connected on site)

General characteristics:

Material:	PE
Standard:	EN 1825

Dimensions:

Set-up area, length:	3,560 mm
Set-up area, width:	1,350 mm
Set-up area, height:	1,655 mm
Required access area, length:	3,300 mm
Required access area, width:	1,350 mm
Required access area, height:	1,625 mm

Tank:

Inlet nominal size (DN):	200
Inlet nominal size (OD):	200 mm
Outlet nominal size (DN):	200
Outlet nominal size (OD):	200 mm
Distance pipe bottom inlet to tank bottom:	1,200 mm
Distance pipe bottom outlet to tank bottom:	1,130 mm
Connection inlet/outlet sockets:	PE-HD pipes in accordance with DIN 19537, HT pipes in accordance with DIN 19560, PP or AS

Coverage features:

Type of cover:	Cover
Cover material:	Polymer
Colour of cover:	black
Tightness:	odour-tight
Locking:	Quick-release closure

Wastewater contents:

Separator contents:	1,100 l
Total volume:	2,600 l
Contents of sludge trap:	1,500 l
Storage quantity of grease:	600 l

Control:

Control unit:	no

Subject to technical changes.
05.04.2025